



TOWNSHIP OF WASHINGTON CONSTRUCTION OFFICE  
211 ROUTE 31 NORTH  
WASHINGTON, NJ 07882  
(908) 835-1732  
(908) 835-1749 fax

[Amount \_\_\_\_\_/Check# \_\_\_\_\_]

NJHC = New Jersey Housing Code  
TOWC = Township of Washington Code  
UFC = Uniform Fire Code  
UCC = Uniform Construction Code

ADDRESS: \_\_\_\_\_

BLOCK: \_\_\_\_\_ LOT: \_\_\_\_\_ CERTIFICATION#: \_\_\_\_\_

OWNER: \_\_\_\_\_ BUYER: \_\_\_\_\_

CONTACT PHONE # \_\_\_\_\_ CONTACT PERSON: \_\_\_\_\_

OPEN PERMITS: Y \_\_\_\_\_ N \_\_\_\_\_ PERMIT # \_\_\_\_\_

- \_\_\_\_\_ 1. Repair or replace front entrance steps and/or  
Front, side or rear of house. NJHC 5:28-1.10(b)
- \_\_\_\_\_ 2. Provide permanent house numbers at least 3" in  
In height to identify the house. TOWC 52-7
- \_\_\_\_\_ 3. Provide 4' high fence with self closing and  
Latching around swimming pool. TOWC 107-4
- \_\_\_\_\_ 4. Roof, doors, window and siding shall prevent  
Weather from entering the house. NJHC 5:28-1.10(d)
- \_\_\_\_\_ 5. Construction without permits: \_\_\_\_\_  
UCC 5:23-2.14(a)
- \_\_\_\_\_ 6. Other: \_\_\_\_\_

FP 7. Install smoke detectors - Contact Fire Prevention  
(908) 689-1208

\_\_\_\_\_ 8\*. Reserved.

\_\_\_\_\_ 9\*. Replace any defective flue piping. NJHC 5:28-1-8(a)

\_\_\_\_\_ 10. Provide handrails, between 34" and 38" from  
Front nosing of stair where there are 4 more  
Risers, no greater than 4" space. NJHC 5-28-1.10(b)

\_\_\_\_\_ 11. Provide guardrails for any platforms more than  
30" above the floor or along open side of  
Stairs. NJHC 5"28-1.10(b)

\_\_\_\_\_ 12\*. Every habitable room shall have at least 2  
Receptacles. NJCH 5:28-1.6(c)

\_\_\_\_\_ 13. Every bathroom shall have a window that opens  
Or exhaust fan vented to the exterior. NJHC 5:28-  
1.7(b)

\_\_\_\_\_ 14\*. Every dwelling is required to have hot water  
And heat. NJHC5:28-1.4(e&f)

\_\_\_\_\_ 15. Cannot have double keyed deadbolts on egress  
Door. NJHC 5:28-1.9

FP 16. Fire extinguisher - Contact Fire Prevention  
(908) 689-1208

\_\_\_\_\_ 17.\* Correct any violations below:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

FP = Fire Prevention

---

Inspector

Date