



TOWNSHIP OF WASHINGTON CONSTRUCTION OFFICE
211 ROUTE 31 NORTH
WASHINGTON, NJ 07882
(908) 835-1732
(908) 835-1749 fax

[Amount _____/Check# _____]
*** COMMERCIAL ***

NJHC = New Jersey Housing Code
TOWC = Township of Washington Code
UFC = Uniform Fire Code
UCC = Uniform Construction Code

ADDRESS: _____

BLOCK: _____ LOT: _____ CERTIFICATION#: _____

OWNER: _____ BUYER: _____

CONTACT PHONE # _____ CONTACT PERSON: _____

OPEN PERMITS: Y _____ N _____ PERMIT # _____

- _____ 1. Repair or replace front entrance steps and/or front, side or rear of structure. NJHC 5:28-1.10(b)
- _____ 2. Provide permanent address numbers at least 3" in in height to identify the location. TOWC 52-7
- _____ 3. Provide 4' high fence with self closing and latching around swimming pool. TOWC 107-4
- _____ 4. Roof, doors, window and siding shall prevent weather from entering the structure. NJHC 5:28-1.10(d)
- _____ 5. Construction without permits: _____
UCC 5:23-2.14(a)
- _____ 6. Other: _____

FP 7. Install smoke detectors - Contact Fire Prevention
(908) 689-1208

_____ 8*. Change of Use - Building Permit required

_____ 9*. Replace any defective flue piping. NJHC 5:28-1-8(a)

_____ 10. Provide handrails, between 34" and 38" from
front nosing of stair where there are 4 more
risers, no greater than 4" space. NJHC 5-28-1.10(b)

_____ 11. Provide guardrails for any platforms more than
30" above the floor or along open side of
stairs. NJHC 5"28-1.10(b)

_____ 12*. Every habitable room shall have at least 2
receptacles. NJCH 5:28-1.6(c)

_____ 13. Every bathroom shall have a window that opens
or exhaust fan vented to the exterior. NJHC 5:28-
1.7(b)

_____ 14*. Every structure is required to have hot water
and heat. NJHC5:28-1.4(e&f)

_____ 15. Cannot have double keyed deadbolts on emergency
egress door and must have push bar NJHC 5:28-1.9

FP 16. Fire extinguisher - Contact Fire Prevention
(908) 689-1208

_____ 17.* Correct any violations below:

FP = Fire Prevention

Inspector

Date